ROAD CONSTRUCTION PLANS FOR PROJECT 3 OF

GREYROCK SUBDIVISON

LAKE LURE RUTHERFORD COUNTY, N.C.

PROJECT OWNER:
RUTHERFORD COUNTY, N.C.

PROPERTY OWNER:
GREYROCK HOMEOWNERS ASSOCIATION



VICINITY MAP

NTS



GENERAL NOTES:

SHEET INDEX

JOB NUMBER: 12008

REV	DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21304 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD CONSTRUCTION PLANS FOR PHASE 2 OF
GREYROCK SUBDIVISION
LAKE LURE RUTHERFORD COUNTY, NC
COVER

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4499 fax: 828.247.4498

SCALE: N.T.S.
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET:
COVER

JOB NUMBER:
11087

REV	DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21280 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR

GREYROCK SUBDIVISION

LAKE LURE — RUTHERFORD COUNTY, NC

OVERALL PROJECT LAYOUT

Odom Engineering PLLC
132 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: 1" = 100'
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET:
OVERALL △

Drawing name: C:\ACAD\SAVE\GREYROCK PHASE 3-070912-RETAINWALLS-2_1_1_1261.dwg Plotted on: Jul 11, 2012 - 1:46pm



NOTE:
CHANNEL FABRIC TO BE NORTH AMERICAN GREEN SC250

NOTE:
CONTRACTOR TO REMOVE AND DISPOSE OF ALL CONSTRUCTION DEBRIS.

PERMANENTLY STABILIZE ALL GRADED AREAS IMMEDIATELY AFTER FINAL GRADING IS COMPLETED ON EACH AREA. ALL SLOPES AND CHANNELS MUST HAVE TEMPORARY GROUND COVER WITHIN 7 DAYS.

PH3-DI1
INLET: 2183.93
INV. OUT: 2179.36 24"

PH3-Pipe-1
43.71' of
24" HDPE Pipe
@ 6.00%

PH3-CHANNEL#2
SLOPE 7.02%
NAG SC250
LINER

PH3-CHANNEL#1
SLOPE 7.02%
NAG SC250
LINER

PROP. TEMP.
CONSTRUCTION
ENTRANCE/EXIT

PH3-DI#8A
INLET: 2227.50
INV OUT: 2224.50 18"

PH3-Pipe-8A
37.37' of
18" HDPE Pipe
@ 1.34%

PROP. RIPRAP
OUTLET PROTECTION

PH3-Pipe-8B
31.73' of
18" HDPE Pipe
@ 1.26%

PH3-DI#8B
INLET: 2225.96
INV. IN-2224.00
INV OUT: 2223.90 18"

PROP. INLET
PROTECTION
TYPICAL

REDI-ROCK WALL #1
APPROX. 75 LF
-INSTALLED PER
MANUFACTURER'S
INSTRUCTIONS

REDI-ROCK WALL #2
APROX.1175 LF
-INSTALLED PER
MANUFACTURER'S
INSTRUCTIONS

PH3-HW1A
INLET: 2152.37
INV. IN: 2147.20

PH3-CULVERT-A
88.80' of
48" Concrete Pipe
@ 12.61%

PH3-HW1B
INV. OUT: 2136.00

SEE SHEET 1 OF 6
SEE SHEET 2 OF 6

1.41 AC.
0.87 AC.
1.37 AC.
1.20 AC.
1.59 AC.
1.34 AC.
1.05 AC.
2.71 AC.

GRAPHIC SCALE
0 25 50 100
1 INCH = 50 FEET

JOB NUMBER:
11087

REV	DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21280 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR
GREYROCK SUBDIVISION
LAKE LURE — RUTHERFORD COUNTY, NC
GREY ROCK ROAD

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: 1" = 50'
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET:
1 OF 6

Drawing name: C:\ACAD\SAVE\GREYROCK PHASE 3-070912-RETAINWALLS-2_1_1_1261.dwg Plotted on: Jul 11, 2012 - 1:47pm



PARTIAL ROAD PROFILE

VERTICAL SCALE: 1" = 5'
HORIZONTAL SCALE: 1" = 50'



Drawing name: C:\ACAD\SAVE\GREYROCK PHASE 3-070912-RETAINWALLS-2_1_1_1261.dwg Plotted on: Jul 11, 2012 – 1:47pm

REFER TO LAKE LURE MANUFACTURER'S INSTRUCTIONS

JOB NUMBER: 11087

REV	DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21180 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR

GREYROCK SUBDIVISION

LAKE LURE — RUTHERFORD COUNTY, NC

GREY ROCK ROAD

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4405 fax: 828.247.4498
NC FIRM# P-0880

SCALE: 1" = 50'
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET: 2 OF 6



PARTIAL ROAD PROFILE

VERTICAL SCALE: 1" = 5'
HORIZONTAL SCALE: 1" = 50'

Drawing name: C:\ACAD\SAVE\GREYROCK PHASE 3-070912-RETAINWALLS-2_1_1_1261.dwg Plotted on: Jul 11, 2012 - 1:48pm

JOB NUMBER: 11087

REV	BY	DATE	DESCRIPTION
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21130 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR

GREYROCK SUBDIVISION

LAKE LURE RUTHERFORD COUNTY, NC

GREY ROCK ROAD

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: 1" = 50'
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET: 2 OF 6



PARTIAL ROAD PROFILE

VERTICAL SCALE: 1" = 5'
HORIZONTAL SCALE: 1" = 50'



NOTE:
CONTRACTOR TO REMOVE AND DISPOSE OF ALL CONSTRUCTION DEBRIS.

NOTE:
CHANNEL FABRIC TO BE NORTH AMERICAN GREEN SC250

PERMANENTLY STABILIZE ALL GRADED AREAS IMMEDIATELY AFTER FINAL GRADING IS COMPLETED ON EACH AREA. ALL SLOPES AND CHANNELS MUST HAVE TEMPORARY GROUND COVER WITHIN 7 DAYS.

Drawing name: C:\ACAD\SAVE\GREYROCK PHASE 3-070912-RETAINWALLS-2_1_1_1261.dwg Plotted on: Jul 11, 2012 – 1:48pm

JOB NUMBER: 11087

REV	BY	DATE	DESCRIPTION
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21260 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR
GREYROCK SUBDIVISION
LAKE LURE — RUTHERFORD COUNTY, NC
GREY ROCK ROAD

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: 1" = 50'
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET: 4 OF 6



NOTES:
1. THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE TOP DRESSING, REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT.
2. WHEN NECESSARY, WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC RIGHT-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE THAT DRAINS INTO AN APPROVED SEDIMENT TRAP OR SEDIMENT BASIN.

TEMPORARY GRAVEL CONSTRUCTION ENTRANCE/EXIT

CONSTRUCTION SPECIFICATIONS

1. Clear the entrance and exit area of all vegetation, roots, and other objectionable material and properly grade it.
2. Place the gravel to the specific grade and dimensions shown on the plans, and smooth it.
3. Provide drainage to carry water to the sediment trap.
4. Gravel to be placed on Geotextile cloth.

CONSTRUCTION SCHEDULE

1. Obtain plan approval and other applicable permits.
2. Install sediment fencing and/or temporary berms for clearing and grubbing phase.
3. Install temporary sediment traps. Ensure access to traps throughout construction.
4. Grade site.
5. Slopes shall have ground cover established within 21 calendar days.
6. Install permanent vegetation on all disturbed areas within 15 working days or no more than 60 calendar days following completion of construction or development.
7. Remove temporary measures only after site is stabilized with vigorous and dense vegetative cover.
8. Estimated time to final stabilization 4 mos.
9. In fill situations contractor shall install a temporary berm above slope to divert any potential runoff that may occur overnight in lieu of inclimate weather.



NOTES:
1. SLOPE SURFACE SHALL BE FREE OF ROCKS, CLODS, STICKS AND GRASS. MATS/BLANKETS SHALL HAVE GOOD SOIL CONTACT.
2. LAY BLANKETS LOOSELY AND STAKE OR STAPLE TO MAINTAIN DIRECT CONTACT WITH THE SOIL. DO NOT STRETCH.

FABRIC SLOPE LINERS

CONSTRUCTION SPECIFICATIONS

1. Begin at top of slope and anchor its blanket in a 6" deep x 6" wide trench. Backfill and compact.
2. Unroll blanket downslope in direction of flow.
3. Overlap edges of rolls 2"-3" and staple every 3'.
4. When blankets must be spliced, place blankets end over end with 6" overlap. Staple through overlapped area approximately 12" apart.
5. Lay blankets loosely and maintain direct contact with soil - do not stretch.
6. Blankets shall be stapled sufficiently to anchor blanket and maintain contact with soil. Staples shall be placed down the center and staggered with the staples placed along the edges. Steep slopes, 1:1 to 2:1 require 2 staples per square yard. Moderate slopes, 2:1 to 3:1, require 1 1/2 staples per square yard. Gentle slopes require 1 staple per square yard.



NOTES:
1. 'La' = LENGTH OF APRON. DISTANCE 'La' SHALL BE OF SUFFICIENT LENGTH TO DISSIPATE ENERGY.
2. APRON SHALL BE SET AT A ZERO GRADE AND ALIGNED STRAIGHT.
3. FILTER MATERIAL SHALL BE FILTER FABRIC OR 6" THICK (MIN.) GRADED GRAVEL LAYER.

OUTLET PROTECTION

CONSTRUCTION SPECIFICATIONS

1. Ensure subgrade for the filter and riprap is at zero grade. Compact any fill required in the subgrade to the density of the surrounding undisturbed material. Low areas in the subgrade on undisturbed soil may also be filled by increasing riprap thickness.
2. Filter cloth, when used, must meet design requirements and be protected from punching or tearing. All overlapping joints should overlap at least 1'.
3. Riprap may be field stone or rough quarry stone. It should be hard, angular, highly weather-resistant and well graded.
4. Construct the apron on zero grade with no overfall at the end. Make the top of the riprap at the downstream end level with the receiving area or slightly below it.
5. Ensure that the apron is properly aligned with the receiving stream and preferably straight throughout its length. If a curve is needed, place it in the upper end of the apron.
6. Immediately after construction, stabilize all disturbed areas with vegetation.

1. All erosion and sediment control practices will be checked for stability and operation following every runoff-producing rainfall but in no case less than once every week. Any needed repairs will be made immediately to maintain all practices as designed.
2. Sediment will be removed behind the sediment fence when it becomes about 0.5' deep at the fence. The sediment fence will be repaired as necessary to maintain a barrier.
3. All seeded areas will be fertilized, reseeded as necessary according to specifications in the vegetative plan to maintain a vigorous, dense, vegetative cover.



INSTALL & MAINTAIN INLET PROTECTION AROUND ALL STORM DRAIN INLETS DURING CONSTRUCTION.

DITCH INLET ADAPTOR

N.T.S.



INSTALL & MAINTAIN INLET PROTECTION AROUND ALL STORM DRAIN INLETS DURING CONSTRUCTION.

JUNCTION BOX

N.T.S.

PERMANENT SEEDING

GRASS-LINED CHANNELS

Kentucky bluegrass	20 lb/ac
Rye (grain)	40 lb/ac
Lime	4000 lb/ac
10-10-10 fertilizer	1200 lb/ac
straw	4000 lb/ac

ALL OTHER SURFACES

Tall fescue	100 lb/ac
Serica lespedeza (Scarified)	30 lb/ac
Kobe lespedeza	10 lb/ac
10-10-10 fertilizer	1000 lb/ac
straw	4000 lb/ac

TEMPORARY SEEDING

SUMMER (May 15 - Aug 15) German millet	40 lb/ac
FALL (Aug 15 - Dec 15) Rye (grain)	120 lb/ac
WINTER/EARLY SPRING (Feb 1 - May 15) Rye (grain)	120 lb/ac
Korean lespedeza	50 lb/ac
Lime	2000 lb/ac
10-10-10	750 lb/ac
straw	4000 lb/ac

SEEDING PROCEDURES:
1. Apply seed, at the rates above, in two intersecting directions. Rake in lightly.
2. Do not seed areas in excess of that which can be mulched on same day.
3. Do not sow immediately following rain, when ground is too dry, or during windy periods.
4. Roll seeded area with roller not exceeding 112 lbs.
5. Immediately following seeding and compacting, apply mulch to a thickness of 1/8 inches. Maintain clear of shrubs and trees.
6. Apply water with a fine spray immediately after each area has been mulched. Saturate to 4 inches of soil.

SEED PROTECTION:
1. Identify seeded areas with stakes and string around area periphery. Set string height to 6 inches.
2. Cover seeded slopes where grade is 4 inches per foot or greater with erosion fabric. Roll fabric onto slopes without stretching or pulling.
3. Lay fabric smoothly on surface, bury top end of each section in 6 inch deep excavated topsoil trench. Provide 12 inch overlap of adjacent rolls. Backfill trench and rake smooth, level with adjacent soil.
4. Secure outside edges and overlaps at 36 inch intervals with stakes.
5. Lightly dress slopes with topsoil to ensure close contact between fabric and soil.
6. At sides of ditches, lay fabric laps in direction of water flow. Lap ends and edges minimum 6 inches.



NOTES:
1. DROP INLET SEDIMENT BARRIERS ARE TO BE USED FOR SMALL, NEARLY LEVEL DRAINAGE AREAS (LESS THAN 5%).
2. THE TOP OF THE STRUCTURE (PONDING HEIGHT) MUST BE WELL BELOW THE GROUND ELEVATION DOWNSLOPE TO PREVENT RUNOFF FROM BY-PASSING THE INLET. EXCAVATION OF A BASIN ADJACENT TO THE DROP INLET OR A TEMPORARY DIKE ON THE DOWNSLOPE OF THE STRUCTURE MAY BE NECESSARY.

GRAVEL DITCH INLET SEDIMENT BARRIER

CONSTRUCTION SPECIFICATIONS

1. Place the stone slope toward the inlet at a 3:1 or flatter slope. A minimum 1 foot wide level area set 4 inches below the drop inlet crest will add further protection against the entrance of material.
2. Stone on the slope toward the inlet should be 3 inches or larger for stability, and 1 inch or smaller on the slope away from the inlet to control flow rate.
3. Wire mesh with 2 inch openings may be placed over the drain grating, but must be inspected frequently to avoid blockage by trash.



TYPICAL SECTION

RIP RAP LINED CHANNEL

CONSTRUCTION SPECIFICATIONS

1. Excavate cross section to grades shown on plans. Overcut for thickness of rock and filter.
2. Place filter fabric or gravel filter layer, and rock as soon as the foundation is prepared.
3. Place rock so it forms a dense, uniform, well-graded mass with few voids. Hand placement may be necessary to obtain good size distribution.
4. No overfall of channel construction should exist. Grass lined channels with riprap bottoms must have a smooth contact between riprap and vegetation.
5. Outlet must be stable.
6. Use a foundation of extra strength filter fabric or and aggregate filter layer.



1. PREPARE SOIL BEFORE INSTALLING BLANKETS, INCLUDING ANY NECESSARY APPLICATION OF LIME, FERTILIZER, AND SEED. NOTE: WHEN USING CELL-O-SEED DO NOT SEED PREPARED AREA. CELL-O-SEED MUST BE INSTALLED WITH PAPER SIDE DOWN.
2. BEGIN AT THE TOP OF THE CHANNEL BY ANCHORING THE BLANKET IN A 6" (15cm) DEEP X 6" (15cm) WIDE TRENCH WITH APPROXIMATELY 12" (30cm) OF BLANKET EXTENDED BEYOND THE UP-SLOPE PORTION OF THE TRENCH. ANCHOR THE BLANKET WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30cm) APART IN THE BOTTOM OF THE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING. APPLY SEED TO COMPACTED SOIL AND FOLD REMAINING 12" (30cm) PORTION OF BLANKET BACK OVER SEED AND COMPACTED SOIL. SECURE BLANKET OVER COMPACTED SOIL WITH A ROW OF STAPLES/STAKES SPACED APPROXIMATELY 12" (30cm) APART ACROSS THE WIDTH OF THE BLANKET.
3. ROLL CENTER BLANKET IN DIRECTION OF WATER FLOW IN BOTTOM OF CHANNEL. BLANKETS WILL UNROLL WITH APPROPRIATE SIDE AGAINST THE SOIL SURFACE. ALL BLANKETS MUST BE SECURELY FASTENED TO SOIL SURFACE BY PLACING STAPLES/STAKES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN GUIDE. WHEN USING OPTIONAL DOT SYSTEM™, STAPLES/STAKES SHOULD BE PLACED THROUGH EACH OF THE COLORED DOTS CORRESPONDING TO THE APPROPRIATE STAPLE PATTERN.
4. PLACE CONSECUTIVE BLANKETS END OVER END (SHINGLE STYLE) WITH A 4"-6" (10cm-15cm) OVERLAP. USE A DOUBLE ROW OF STAPLES STAGGERED 4" (10cm) APART AND 4" (10cm) ON CENTER TO SECURE BLANKETS.
5. FULL LENGTH EDGE OF BLANKETS AT TOP OF SIDE SLOPES MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30cm) APART IN A 6" (15cm) DEEP X 6" (15cm) WIDE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.
6. ADJACENT BLANKETS MUST BE OVERLAPPED APPROXIMATELY 2"-5" (5cm-12.5cm) (DEPENDING ON BLANKET TYPE) AND STAPLED. TO ENSURE PROPER SEAM ALIGNMENT, PLACE THE EDGE OF THE OVERLAPPING BLANKET (BLANKET BEING INSTALLED ON TOP) EVEN WITH THE COLORED SEAM STITCH™ON THE BLANKET BEING OVERLAPPED.
7. IN HIGH FLOW CHANNEL APPLICATIONS, A STAPLE CHECK SLOT IS RECOMMENDED AT 30 TO 40 FOOT (9m-12m) INTERVALS. USE A DOUBLE ROW OF STAPLES STAGGERED 4" (10cm) APART AND 4" (10cm) ON CENTER OVER ENTIRE WIDTH OF THE CHANNEL.
8. THE TERMINAL END OF THE BLANKETS MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" (30cm) APART IN A 6" (15cm) DEEP X 6" (15cm) WIDE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.



CRITICAL POINTS
A. OVERLAPS AND SEAMS
B. PROJECTED WATER LINE
C. CHANNEL BOTTOM/SIDE SLOPE VERTICES

NOTE:
* HORIZONTAL STAPLE SPACING SHOULD BE ALTERED IF NECESSARY TO ALLOW STAPLES TO SECURE THE CRITICAL POINTS ALONG THE CHANNEL SURFACE.

** IN LOOSE SOIL CONDITIONS, THE USE OF STAPLE OR STAKE LENGTHS GREATER THAN 6" (15 cm) MAY BE NECESSARY TO PROPERLY ANCHOR THE BLANKETS.

GENERAL NOTES:
1. ONLY DISTURB CLEAR OR GRADE AREAS NECESSARY FOR CONSTRUCTION. FLAG OR OTHERWISE DELINEATE AREAS NOT TO BE DISTURBED. EXCLUDE VEHICLES AND CONSTRUCTION EQUIPMENT FROM THESE AREAS TO PRESERVE NATURAL VEGETATION.
2. CLEAR AND GRUB AREAS TO BE FILLED TO REMOVE TREES, VEGETATION, MUCK, ROOTS, OR OTHER OBJECTIONABLE MATERIAL THAT WOULD AFFECT THE PLANTED STABILITY OF THE FILL.
3. PLACE FILL IN LAYERS NOT TO EXCEED 6" IN THICKNESS AND COMPACT THE LAYERS AS REQUIRED TO TO REDUCE EROSION, SLIPPAGE, SETTLEMENT, OR OTHER RELATED PROBLEMS.
4. KEEP DIVERSIONS AND CHANNELS AND OTHER WATER CONVEYANCE MEASURES FREE OF SEDIMENT AT ALL TIMES.
5. ROUGHEN THE SURFACE OF ALL SLOPES DURING THE CONSTRUCTION OPERATION TO RETAIN WATER, INCREASE INFILTRATION, AND FACILITATE VEGETATION ESTABLISHMENT.
6. PERMANENTLY STABILIZE ALL GRADED AREAS IMMEDIATELY AFTER FINAL GRADING IS COMPLETED ON EACH AREA. 2:1 OR STEEPER SLOPES MUST HAVE TEMPORARY GROUND COVER WITHIN 7 DAYS. 3:1 SLOPES OR FLATTER SLOPES MUST HAVE TEMPORARY GROUND COVER WITHIN 14 DAYS

MAINTENANCE PLAN

1. All erosion and sediment control practices will be checked for stability and operation following every runoff-producing rainfall but in no case less than once every week. Any needed repairs will be made immediately to maintain all practices as designed.
2. Sediment will be removed behind the sediment fence when it becomes about 0.5' deep at the fence. The sediment fence will be repaired as necessary to maintain a barrier.
3. Ensure temporary sediment trap is cleared once sediment reaches cleanout mark.
4. All seeded areas will be fertilized, reseeded as necessary according to specifications in the vegetative plan to maintain a vigorous, dense, vegetative cover.



TURN OUT DITCH



SUPER SILT FENCE NOTES:
1. CHAIN LINK FENCE SHALL BE CONSTRUCTED IN ACCORDANCE WITH APPROVED SPECIFICATIONS. CHAIN LINK FENCE SHALL BE FASTENED SECURELY TO THE POSTS WITH WIRE TIES OR STAPLES.
2. POSTS NEED NOT BE SET IN CONCRETE.
3. THE FILTER FABRIC SHALL BE FASTENED TO THE CHAIN LINK FENCE WITH WIRE TIES EVERY 24" AT THE TOP AND MID SECTION.
4. FABRIC AND FENCE SHALL BE EMBEDDED 12", MINIMUM, INTO THE GROUND.
5. A 6", MINIMUM, OVERLAP SHALL BE PROVIDED WHERE TWO SECTIONS OF FABRIC ADJOIN. THE OVERLAPPED FABRIC SHALL BE FOLDED TOGETHER AND ATTACHED TO THE CHAIN LINK FENCE.
6. 4"x4" PRESSURE TREATED POSTS MAY BE SUBSTITUTED FOR METAL FENCE POSTS WITH THE APPROVAL OF THE ENGINEER.
7. THE LENGTH OF SLOPE ABOVE THE FENCE SHALL NOT EXCEED 400 FEET IN STEEP TERRAIN, IN FLATTER AREAS THE LENGTH CAN BE EXTENDED WITH THE APPROVAL OF THE ENGINEER.

SUPER SILT FENCE



PROPOSED PIPE WITHPROPOSED DITCH INLET

N.T.S.

NOTES:
1. ALL CONCRETE SHALL BE 4000 PSI MINIMUM.
2. REINFORCEMENT STEEL SHALL MEET ASTM-A615 GRADE 60 WITH 2" MINIMUM CLEARANCE.

INSIDE PIPE DIAMETER	REINF.	LBS.	W1	W2	H1	H2	D	E
12", 15", 18"	NO. 4	2060	44"	64"	23"	42 1/2"	18 1/2"	27"
21", 24"	NO. 4	3100	50"	85"	31"	56"	24"	33"
27", 30", 36"	NO. 4	5940	64"	108"	41"	72"	36"	49"
42", 48"	NO. 4	8040	79"	150"	52"	79"	40"	64"
54", 60", 72"	NO. 4, NO. 5	16000	105"	161"	60"	90"	48"	90"

PRECAST CONCRETE HEADWALL

JOB NUMBER: 12008

REV	DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21124 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR
GREYROCK SUBDIVISION
LAKE LURE — RUTHERFORD COUNTY, NC
ECP DETAILS

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: N.T.S.
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET: 5 OF 6



CROWNED CROSS SECTION



ELEVATED CROSS SECTION



CROWNED CROSS SECTION W/ WALL AND C&G



CROWNED CROSS SECTION W/ WALL NO C&G



CROWNED CROSS SECTION



NOTES:
1. CONTRACTION JOINTS SHALL BE PROVIDED AT 10' INTERVALS.
2. 1/2 INCH EXPANSION JOINT SHALL BE PROVIDED AT INTERVALS NOT TO EXCEED 100 FEET, AT THE ENDS AND MID-POINT OF RETURNS, AND AT ANY POINT WHERE THE NEW CURB AND GUTTER ABUTS OTHER CONCRETE STRUCTURES (SEE SIDEWALK DETAILS)

18" CURB AND GUTTER

N.T.S



PIPE BEDDING DETAIL

RCP & HDPE



SCALE: NTS	S&ME	TYPICAL UNDERCUT DETAIL **GREY ROCK** PROJECT 1 LAKE LURE, NORTH CAROLNA	FIGURE NO: 1
CHECKED BY: LD	GREENVILLE, SC 864.574.2360		
DRAWN BY: MR	SPARTANBURG, SC 864.232.8987		
DATE: 4-3-12		JOB NO: 1263-12-063	

C:\Users\MRevis\Desktop\Undercut.dwg, 4/3/2012 2:48:49 PM, 1:1



SYMMETRICAL CUL-DE-SAC

NO CURB & GUTTER

NTS

JOB NUMBER: 12008

REV	BY	DATE	DESCRIPTION
1			
2			
3			
4			
5			

I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF NORTH CAROLINA AS SIGNIFIED BY MY HAND AND SEAL.

NORTH CAROLINA PROFESSIONAL SEAL 21130 ENGINEER DAVID ODOM 07/09/12

CERTIFICATION

ROAD LAYOUT PHASE 3 PLANS FOR

GREYROCK SUBDIVISION

LAKE LURE RUTHERFORD COUNTY, NC

ECP DETAILS

Odom Engineering PLLC
152 East Main Street, Forest City, N.C. 28043
ph: 828.247.4495 fax: 828.247.4498
NC FIRM# P-0880

SCALE: N.T.S.
DATE: 07/09/12
DRAWN BY: JTP
CHECKED BY: DWO
PROJECT MGR: DWO
SHEET:
5 OF 6